

Bologna, 17/03/2017

IBIX s.r.l.
Via La Viola 2
48022 S. Maria in Fabriago
(RA)

TEST LABORATORY

TEST REPORT No. 3478/17

Requested by:	IBIX s.r.l. Via La Viola 2 48022 S. Maria in Fabriago (RA)
On (date):	06/03/17
For the sample marked:	"TECNOSUPPLY POLYFUSION POLYFUSION".

The results reported relate only to the samples tested.

No responsibility is taken for the accuracy of the sampling unless it is done under our own supervision.

**The reproduction of this test report is only authorized in the form of a complete photographic facsimile.
Our written approval is necessary for any partial reproduction.**

This test report consists of 3 pages this cover included.



CENTRO CERAMICO

Test Report No. 3478/17

Date 17/03/2017

Page 2 of 3

Description of the sample:	Multilayer panel 50 x 100 x 1.8 cm marked "TECNOSUPPLY POLYFUSION POLYFUSION".
Manufacturer:	-----
Sampling details	
- Where:	-----
- Date:	-----
- By whom:	CUSTOMER
- How (methods):	-----
Date of receipt in laboratory:	09/03/17

TESTS PERFORMED :

			Date of starting	Date of ending
<input checked="" type="checkbox"/>	DIN 51130 (06/2004)	Determination of the anti - slip properties – Workrooms and fields of activities with raised slip danger, walking method – ramp test	10/03/17	10/03/17



DIN 51130 (06/2004)- Determination of the anti - slip properties – Workrooms and fields of activities with raised slip danger, walking method – ramp test

Surface characteristics

Smooth


Profiled

Structured

Rough

OPERATIVE CONDITIONS

Fixing scheme



↓
Walking direction

RESULTS

Average total acceptance angle:

9.4°

Movement area (cm³/dm²):

CLASSIFICATION (BGR 181- 10/2003)

Group of anti - slip properties:

R9

Movement area evaluation group:

Pietro Bruzzi
Technical verification



Prof. Maria Chiara Bignozzi

Director